


Annexure-A

Pressure Transmitter Specifications (for RDS Tank)				
S.No.	Catagery	Parameter	Value	Remarks
1	General	TAG No.	PT-15-001,002,003 & 005	
2		Location	RDS Tank	
3		Temp. (Max)	150 Deg.C	
4	Sensor	Sensing Element	Diaphragm	
5		Element MOC	SS 316L	
6		Filling Fluid	Liquor	
7		Capillary Length	3mtrs	
8	Transmitter	Type	Electronic Smart with HART	
9		Calibration Range	0 to 1.6 bar	
10		Accuracy	+/- 0.075%	
11		Housing	AL	
12		Power Supply	24V DC, 2-wire	
13		Transmitter Output	4-20 mA, 2-wire	
14		Local Indication	Yes	
15		Local Keypad	Yes	
16		Zero Adjustment	Yes	
17		Area Classification	Safe Area	
18		Enclousure	IP 65	
19		Mounting	2" Pipe Bracket	
20		Cable Entry	1/2" NPT(F)	
21		Make	ABB, E&H	


K. Lakshmi Rangaiah
 Chief Supdt (Ins)
 UCIL-Tummalapalle