

Annexure: Passive Fire Protection System

Sl.No	Description	Unit	Qty
1	FP 05 Firestop board, Fire Rating: 2 Hrs, Fire Barrier system is having high density Mineral Wool, Dimension: 1200mm x 600mm x 50mm. TEST: UL 1479 02 hrs T&F rating, FM approved , GB23864, ASTM E84, ASTM E662. MAKE: INCA / Hitech Sealing and Insulating Industries	Sq Mtr	50
2	Mortar CFS01, Non Intumescent compound comprised of gypsum and cement. TEST: UL 1479 3hrs, T and L Rating, CAN/ULC S115 3 hrs, FTH Rating, G23864. Make:INCA / Hitech Sealing and Insulating Industries	Kg	100
3	DC 6150 Cable Coating. Specifications: Colour: White, Odour: Mild Latex, Gloss Level: Matt, Specific gravity: 1.5 +-0.01, Solid by Weight: 70-76%, pH Value: 6-8, Drying Time: Depending on ambient condition, Dry to touch: 2-4 hrs, Dry Through: 2-4 days, Application Airless spray, brush or roller, Typical Thickness: 1000 micron wft (39.5 Mils) Equivalent to 640 micron DFT(25 mills) 25Kgs/Pail. Test: FM approval Class 3971, IEEE 383, IEC60332-3A, IEEE1202. Make: INCA / Hitech Sealing and Insulating Industries	Kg	225

Handwritten signature
07/12/17