

त. : यूसील, जादुगोड़ा माइन्स
Cable : UCIL, Jaduguda Mines

PR# List
1. 7/PR175375

यूरेनियम कारपोरेशन ऑफ इंडिया लिमिटेड, जादुगोड़ा

(भारत सरकार का संस्थान)

डाकघर : जादुगोड़ा माइन्स, झारखण्ड-832 102

URANIUM CORPORATION OF INDIA LIMITED

(A Government of India Enterprise)

P.O. Jaduguda Mines, Jharkhand - 832 102

पूछताछ / Enquiry

फोन / Phone : (0657) 2730122
2730222, 2730353

फैक्स / Fax : (0657) 2730322
(0657) 2731332

E-mail : jadpur@ucil.gov.in

सेवा में / To

लिफाफें पर यह संदर्भ लिखें
QUOTE THIS REFERENCE ON THE COVER
1/PE170017/7

पूछताछ सं० / Enquiry No.

16/02/2017

तारीख / Date

15/03/2017

नियत तारीख / Due Date

महाशय,

कृपया निम्नलिखित सामान की पूर्ति के लिए दिए गए हमारे पन्ने के दूसरी ओर अनुदेशों के अनुसार अपने भाव भेजें। अपने भाव भंडार "क्रय विभाग" को उपयुक्त पते पर नियत तारीख से पूर्व डाक द्वारा भेजें।

Dear Sir,

Kindly submit your quotation made out as per instruction overleaf for the supply of stores detailed below. The quotation should be posted to the "Purchase Department" at the above address to reach before the due date.

क्रम सं० Sl. No.	सामान का नाम / DESCRIPTION OF STORES	मात्रा QUANTITY
1	POLYMER PIN INSULATOR 33KV GRADE ()	42 Number
2	POLYMER DISC INSULATOR 33KV GRADE ()	16 Set
3	POLYMER POST INSULATOR 33KV GRADE	10 Number
<p>1. Bidder Should submit their offer as per terms & conditions given under Annexure 1, 2 & 3 [ANNEXURE -1 (Pre -Qualification Part), ANNEXURE-2 (Techno-commercial Cum Price Part) & Annexure -3 (Pre-Qualification Criteria)] Details specification as per annexure -4 (a) (b), (c) attached. ()</p> <p>Note : 1. Please quote your rate in figure and word without overwriting / cutting and submit your offer in duplicate for consideration. 2. FAX OFFER WILL NOT BE ACCEPTED. 3. Your offer should be valid for minimum 90 days. 4. Entire Bank charges, if any will be borne by you. 5. Our terms of payment will be full within 30 days from the date of Receipt & acceptance of materials.</p>		

अनुलग्नक
Enclosures

भवदीय / Yours faithfully

कृते यूरेनियम कारपोरेशन ऑफ इंडिया लिमिटेड
For URANIUM CORPORATION OF INDIA LIMITED

CC To:

USHA MAHTO

File

Post. Purchase Officer

Part I (Pre-Qualification Part)

- 1) Bidders who are interested in supply are required to submit their offer as per address indicated in our enquiry in two parts. Part-I consisting of Pre-Qualification Part and Part-II consisting of Techno-commercial Cum Price Part. Bidder should submit both parts in separate sealed envelope superscribing Part-I, Part-II and bidders name and address on top of the envelope. These two parts i.e. one Pre-Qualification Part and one Techno-commercial cum Price Part should be submitted in separate envelope superscribing (a) Tender No. & due date (b) Name and Address of Bidders. Bidders who are not meeting the pre-qualification criteria and also not accepted Terms & Conditions of NIT (as per Annexure-2), their offer will be rejected without making any further communication with them.
- 2) **Pre -Qualification Criteria:** (As per Annexure-3).
(Bidder must submit all the required information and documents in support of PQC failing which their offer will be rejected.)
- 3) All terms & conditions indicated in Part-II is required to be accepted by the bidders in totality in Part-I (Pre-qualification Part) failing which their offer will be rejected and price part shall not be opened and Bidder should also indicate one line confirmation in Pre- qualification part that **"All NIT terms & conditions indicated in Techno-commercial cum Price part (as per Annexure-2) have been agreed by us in totality"**

Above required information shall be furnished in Part I (Pre-Qualification Part)


(USHA MAHTO)
ASST. PURCHASE OFFICER

Part-II (Techno-commercial Cum Price Part)NIT TERMS & CONDITIONS

- 1) Following terms & conditions is required to be accepted by the participated bidders in totality and also mention one line confirmation in Part-I (Pre-qualification Part) that **"All NIT terms & conditions indicated in Technommercial cum Price part (as per Annexure 2) have been agreed by us in totality"** Failing which their offer will be rejected and price part shall not be opened.
- 2) **BASIS OF EVALUATION:** offer submitted by the bidder shall be in two part .Evaluation of L1 (Lowest) bidder shall be done based on their lowest landed quoted rate subject to qualify in Part I i.e. Pre Qualification Part. Bidder should quote their rate both figures as well as in words. In case of any discrepancy in figure and words rate then rate written in words will be final.
- 3) Bidders whose name exists in our **dormant list (Adverse Remarks Register)** their offer will not be considered.
- 4) **PRICE TERM:** Bidders should submit their offer on F.O.R. destination basis only for supply of materials at our Jaduguda/Narwapahar/Turamdih Stores. No other price term is acceptable. All freight and insurance charges will be borne by the bidder.
- 5) **VALIDITY:** Offer validity should be 120 days from the due date of tender.
- 6) **PAYMENT TERM:** Bidder should quote payment term as "100% payment will be made within 30 days from the date of receipt & acceptance of material "
- 7) **QUANTITY:** Quantity or stores indicated herein is approximate only and purchaser is not bound to order of full quantity and your offer should be valid for part quantity also.
- 8) **Sample:** Sample, if called for , shall be submitted free of all charges and the same may not be returned to the tenderer.
- 9) **DELIVERY SCHEDULE :** Bidder should indicate their best delivery schedule.
- 10) Offers must be submitted positively within the due date. Tenders will not be accepted after 11.30 A.M on the due date of submission of offers.
- 11) Bidders who are interested to participate in the tender opening may do so at their own arrangement on scheduled due date and Time.
- 12) You will confirm that the item is excisable in nature. Supporting document for reimbursement of payment against Excise Duty will be enclosed along with bill. In case the item is of imported origin supporting documents for reimbursement of payment against CD/CVD will be required to be submitted along with bill.
- 13) **AGREED LIQUIDATED DAMAGE :** If successful tenderer fails to execute the order within the agreed delivery schedule, he shall be liable to pay as agreed liquidated damages a sum@ ½% of the order value per week or part thereof of delay subject to a maximum of 5%. In case of delay beyond 10 weeks UCIL reserves the right to cancel the order and levy penalties.
- 14) **CANCELLATION OF ORDER :** It will be your endeavour to execute the purchase order to our satisfaction. In case of your failure to do so, the order is liable to be cancelled.
- 15) **FORCE MAJEURE:** In the event of strikes / lockouts, closure of work (whole or partial) breakdown of machinery, act of god or any other cause beyond our control, preventing or hindering the normal operation, we shall be at liberty to cancel this

order at any time before receipt of goods without being liable to the supplier for damages or other claims.

- 16) **DISPUTES** : Both parties agree in, disputes arising out of this order may be settled by arbitration, in accordance with the Indian Arbitration Act, 1940 & its subsequent amendment, by a sole arbitrator who shall be appointed by the Chairman & Managing Director of this Corporation (UCIL).
- 17) **JURISDICTION**: This agreement order shall be deemed to have been executed at Jaduguda, Dist: East Singhbhum, Jharkhand and it is subject to the jurisdiction of Court of law in Ghatsila only, irrespective of anything to the contrary that may be mentioned in the tender / quotation.
- 18) Preference will be given to parties as per Govt. guidelines in vogue.

(USHA MAHTO)
ASST. PURCHASE OFFICER

Pre-Qualification Criteria :

- 1) The bidder should be manufacturer or authorized dealer for the tendered items.
 - a. In case of manufacturer, evidence of manufacturing or catalogue must be submitted.
 - b. In case of authorized dealer, a copy of valid authorization certificate from the principal / manufacturer must be submitted.
- 2) Bidder should submit Purchase Order copies of similar type of items supplied to any organization during last 3 financial years ending 31.03.2016. Single PO copy of not less than **Rs.50,000/-** to be enclosed.
- 3) Sales Tax / VAT registration no. to be furnished.

(USHA MAHTO)
ASST. PURCHASE OFFICER

Technical Specification for 33KV Polymer Pin Insulator

- i) Nominal system voltage : 33KV
- ii) Highest system voltage : 36KV
- iii) System Frequency : 50HZ
- iv) No of phase : 3
- v) Type of Insulator : Polymeric Composite Insulator
- vi) Material of FRP rod : Boron free ECR , Hydrolysis resistant
- vii) Material of shed : Silicon Rubber
- viii) Material of end fittings : SGCI/MCI
- ix) Dry flashover voltage : 130KV
- x) Wet Flashover Voltage : 90KV
- xi) Creepage Distance : 900mm
- xii) Min. failing Load : 10KN
- xiii) Dry power frequency withstand voltage : 95KV
- xiv) Wet Power frequency withstand voltage : 75KV
- xv) Power Frequency puncture withstand voltage : 180KV
- xvi) Polymer pin insulator shall be suitable for installation at 33KV overhead line having single rail pole structure employed with horizontal cross arm. ^(100x50mm) Diameter of hole made on existing cross arm for installation of insulators is 25mm .
- xvii) Guarantee : 12 months from the date of commissioning at site or 18months from the date of supply .
- xviii) Test report of insulators shall be furnished by the bidder alongwith the bid .



Technical Specification for 33KV Polymer Disc Insulator

- i) Nominal system voltage : 33KV
- ii) Highest system voltage : 36KV
- iii) System Frequency : 50HZ
- iv) No of phase : 3
- v) Type of Insulator : Polymeric Composite Insulator
- vi) Material of FRP rod : Boron free ECR , Hydrolysis resistant
- vii) Material of shed : Silicon Rubber
- viii) Material of end fittings : SGCI/MCI
- ix) Type of metal end fittings : Tongue & Clevis
- x) Dry flashover voltage : 130KV
- xi) Wet Flashover Voltage : 90KV
- xii) Creepage Distance : 900mm
- xiii) Min. failing Load : 70KN
- xiv) Dry power frequency withstand voltage : 95KV
- xv) Wet Power frequency withstand voltage : 75KV
- xvi) Power Frequency puncture withstand voltage : 180KV
- xvii) Polymer disc insulator shall be suitable for installation at 33KV overhead line having double rail pole structure .
- xviii) Guarantee : 12 months from the date of commissioning at site or 18months from the date of supply .
- xix) Test report of insulators shall be furnished by the bidder alongwith the bid .



Technical Specification for 33KV Polymer Post Insulator

- i) Nominal system voltage : 33KV
- ii) Highest system voltage : 36KV
- iii) System Frequency : 50HZ
- iv) No of phase : 3
- v) Type of Insulator : Polymeric Composite Insulator
- vi) Material of FRP rod : Boron free ECR , Hydrolysis resistant
- vii) Material of shed : Silicon Rubber
- viii) Material of end fittings : SGCI/MCI
- ix) Dry flashover voltage : 130KV
- x) Wet Flashover Voltage : 90KV
- xi) Creepage Distance : 900mm
- xii) Min. failing Load : 10KN
- xiii) Dry power frequency withstand voltage : 95KV
- xiv) Wet Power frequency withstand voltage : 75KV
- xv) Power Frequency puncture withstand voltage : 180KV
- xvi) Polymer post insulator shall be suitable for installation at 33KV overhead line having double rail pole structure
- xvii) Guarantee : 12 months from the date of commissioning at site or 18months from the date of supply.
- xviii) Test report of insulators shall be furnished by the bidder alongwith the bid .

A handwritten signature in black ink, appearing to be 'R. S. S.', is located in the lower right quadrant of the page.