

DETAIL OF CAPACITOR BANK

Make-ABB  
No-3100118FE264  
Int fuse-NA  
Type-CHD  
CN-6.10micro farad +7  
IN-8.2A  
FN-50HZ  
UN-7400V  
QN-105KVAR  
Ins. Level-22/60KV  
Temp. Cat- -10Deg. Centigrade  
Discharge device- Internal  
Standard-IS13925  
Phase-3,Y  
Wt.-38kg  
Year-2004  
CAPACITOR/PP/Faradol(jarylec)-NONPCB Impregnated

*Usha*  
उषा महतो  
USHA MAHTO  
सहायक क्रय अधिकारी  
Asst. Purchase Officer

CC To:

File

USHA MAHTO  
Asst. Purchase Officer